



U3802



60 Ampere Non-fused Alternating Current Disconnect Pull Out

SPECIFICATIONS

Brand Name	Milbank
Type	Air Conditioner Disconnect
Special Features	10 Horse Power
Application	Metering Accessory
Standard	UL Listed;Type 3R
Voltage Rating	Up to 240 Volts Alternating Current
Amperage Rating	60 Ampere
Interrupt Rating	10,000 Ampere Interrupting Capacity
Number Of Poles	2
Trip Type	None
Contact Configuration	Pull Out
Contact Rating	60 Ampere Up to 240 Volts Alternating Current
Connection	Pullout

APPEARS IN

Canadian Products

Ameren Service Area

Florida

Meter Equipment Group

Alliant Energy and Mid-American Energy

Commonwealth Edison Service

Flyer_KCPL CT Cabinets

Ohio

Tennessee Area

Upper New York

Western Region

DTE Energy_Consumers Energy

Indiana

Upper Midwest

New England

Enclosure	Painted Steel
Mounting	Surface Mount
Size	2.85 x 5 x 7.5
Conduit Connection	Knockouts
Height	6 IN
Length	5.2 IN
Width	2.85 IN

IMPORTANT NOTICE: Utility requirements for this equipment may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

