

TeSys D Overload Relay Accessories

Table 18.73: Mounting Kits and Plates^[1]



LA7D901



LA7D03

Description	For use with overload relays:	Cat. No.
Separate mounting kits for mounting to 35 mm DIN rail or for panel mounting with screws	LRD01-35 and LR3D01-35 (Not UL/CSA recognized)	LAD7B10
	LRD01-35 and LRD01-35 for ring tongue terminals	LAD7B106
	LRD04L-32L, LR3D04L-32L, and LR9D01-32	LAD7B205
Mounting plates for screw mounting at 110 mm (4.3 in.) centers	LRD3•••, LR3D3•••, LR2D35••	LA7D3064
	LRD01-35, LR3D01-35, LR2D15••	DX1AP25
	LRD3•••, LR3D3•••, LR2D35••	LA7D902

Table 18.74: Accessories

Description	For use with	Standard Packaging	Catalog Number
Prewiring kit allows direct connection of the N.C. contact of relay LRD01-D32 or LR3D01-D32 to the contactor	LC1D09 to D18	10	LAD7C1
	LC1D25 to D38	10	LAD7C2
Stop button locking device	All relays except LRD01-D32, LR3D01-D32 and LR9D	10	LA7D901
Remote stop/tripping or electrical reset ^[2]	LRD01-D32, LR3D3, LR3D01-D32, LR3D3	1	LAD703 ^[3]
	All relays except LRD01-D32, LR3D01-D31	1	LA7D03 ^[3]
Reset by flexible cable 500 mm (19.6 in.)	LRD01-D32, LR3D3, LR3D3	1	LAD7305

Table 18.75: Control Circuit Voltages for LA7D03 and LAD703

Volts	12	24	48	110	220/230	380/400	415/440
AC 50/60 Hz	J ^[4]	B	E	F	M	Q	N
DC	J	B	E	F	M	—	—

TeSys F Overload Relay Accessories

Table 18.76: Mounting Plate for Overload Relay




LA7F90•

For use with relays	Catalog Number
LR9F5•57, F5•63, F5•67, F5•69, F5•71, F57, F63, F67, F69, and F71	LA7F901
LR9F7•75, F7•79, F5•81, F75, F79, and F81	LA7F902

These clear plastic protective shrouds are an effective means to meet international finger-safe requirements for power terminals. They are designed to be used with power cables that have been bolted to the terminal.

NOTE: The protection shrouds do not attach to contactors or overloads utilizing DZ2F lug kits.

Table 18.77: Power Terminal Protection Shrouds, Single-Pole



LA9F70•

For use with relays	Catalog Number
LR9F5•57, F57	LA9F701
LR9F5•63, F5•67, F5•69, F63, F67, F69	LA9F702
LR9F5•71, F71	LA9F705
LR9F7•75, F7•79, F7•81, F75, F79, F81	LA9F703

Table 18.78: Power Terminal Protection Shrouds, 3-Pole

For use with relays	Catalog Number
LR9F5•57, F5•63, F5•67, F5•69, F57, F63, F67, F69	LA7F701
LR9F5•71, F71	LA7F702
LR9F7•75, F7•79, F7•81, F75, F79, F81	LA7F703

Table 18.79: Connection Accessories (for Mounting Overload Relays Beneath Reversing Contactors)^[5]



LA7F701

Application	Set of 3 Busbars Catalog Number
For relays	
LR9F5•57, F5•63, F5•67, F5•69, F69, F71	LA7F401
LR9F5•57, F5•63	LA7F402
LR9F5•71, F71	LA7F407
LR9F5•71, F71	LA7F403
LR9F7•75, F5•79, F75, F79	LA7F404
LR9F7•81, F81	LA7F404
LR9F7•75, F7•79, F7•81, F75, F79, F81	LA7F405
LR9F7•81, F81	LA7F406
For contactor	
LC1F115	LA7F401
LC1F150 and F185	LA7F402
LC1F185	LA7F407
LC1F225 and F265	LA7F403
LC1F225 to F400	LA7F404
LC1F400	LA7F404
LC1F500	LA7F405
LC1F630 and F800	LA7F406

[1] When using mounting plates, separate mounting kits are also required.
 [3] Part number to be completed by adding coil voltage code, (for example, LAD703F).
 [4] Not available for LRD01-D32, LR3D01-D32.
 [5] Mounting plate required.